

TEST REPORT n° 17192

Acceptation n° 6456 del 04-09-08

CLIENT: GEOPLAST S.P.A.
VIA MARTIRI DELLA LIBERTA' 6/8
35010 GRANTORTO (PD)

OBJECT: Factory product control

TYPE OF SAMPLE: Molds for ventilated crawl space

SAMPLE: Molds H27 base 50x50cm

FACTORY: Factory in Grantorto (PD)

SAMPLING: Executed by producer

DELIVERY SAMPLES DATE: 04-09-08

TESTS: 1) Determination of resistance to concentrated load (UNI 9730-3:1990 - D.M. 09/01/96
All. 7 mod.)

TESTING DATE: from 10-09-08 to 10-09-08

PHOTO SAMPLE:



TEST REPORT n° 17192


Acceptation n° 6456 del 04-09-08

TEST 1): DETERMINATION OF RESISTANCE TO CONCENTRATED LOAD (UNI 9730-3:1990 - D.M. 09/01/96 All. 7 mod.)


Procedure: The load was applied with a prismatic section 50x50 mm as requested by the client.
The load was applied at the center of the sample up to failure by rupture of the specimens.

Sample n°	Maximum Load kN
1	1,60
2	1,50
3	1,65
4	1,65
5	1,65
6	1,70
7	1,70
8	1,60
9	1,50
10	1,55

Monte di Malo, 16-09-08



The experimenter
Dott. Andrea Zanrosso



Building Product Sector
The Director
dott. geol. Danilo Belli

This test report refers only to samples tested only and may not be reproduced unless prior written permission of the laboratory.